

**DIVISION 4 MASONRY**

<u>Section No.</u>	<u>Title</u>	<u>Comments</u>
04 05 00	MORTAR AND MASONRY GROUT	1. Mortar shall be 1,800- psi min. 2. Grout shall be 2,500 psi min. 3. “Dry-Block” additive required.
04 05 23	MASONRY ACCESSORIES	1. All accessories shall be galvanized.
04 21 13	BRICK MASONRY	1. Use of brick masonry encourage for building exteriors.
04 21 23	CLAY UNIT MASONRY	1. Minimum f 'c 2,500-PSI.
04 22 00	CONCRETE UNIT MASONRY	1. Minimum f 'c 1,350-psi. 1,500-psi 2. “Dry-Block” additive req'd. 3. No split-face exterior units. Smooth or polished face finish preferred.
04 23 00	GLASS UNIT MASONRY	1. Glass block not allowed.

**NOTES:**

1. Seal all exposed masonry surfaces.
2. See 09 96 23 GRAFFITI RESISTANT COATINGS regarding anti-graffiti coatings for exterior masonry.
3. Provide control joints in masonry walls as required. **Review very carefully!**  
**Align with joints in slab-on –grade.**
4. All masonry caps and sills exposed to weather are to be sloped to drain and flashed with sheet metal.
5. See 32 14 00 for Brick Pavers.